


FNI IOL-106-002-K20 manual

1. Connection diagram As shown in Figure



Picture 1

1. IO-Link|interface

2. Digital I/O Terminal Blocks

3. 24V terminal block

4. GND terminal

5 Status LED: Digital I/O point 16

6 Status LED:|IO-Link

7 Status LED:|Power


8 Status LEDs:|Actuator

2. IO-Link interface diagram

As shown in picture 2.

M12, class A, male

M12, A类, 公头



Pin	Illustrate
1	Power supply, +24V
2	Actuator power supply, +24V
3	GND
4	C/Q, IO-Link data transfer channel

Picture 2

3. IO-Link data

3.1 Parameter

As shown in Table 1-1. Surface 1-1

Data Ztransmission baud rate	COM2 (38 4kbit/s)
Frame type	2 V
Minimum cycle time	3ms
Process data cycle time	3ms, consistent with minimum cycle time
Process data length	2 bytes output

3.2 Process data/output data

As shown in Figure 3.

Bit	0								1							
	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
Describe	Digital input point8	Digital input point7	Digital input point6	Digital input point5	Digital input point4	Digital input point3	Digital input point2	Digital input point1	Digital input point16	Digital input point15	Digital input point14	Digital input point13	Digital input point12	Digital input point11	Digital input point10	Digital input point9

Picture 3

E. g:

The output start address assigned in the configuration project is 64, then the address of the first point is 64.0

The 16th point address is 65.7.

3.3 Parameter data/request data

As shown in Figure 4.

	DPP	SPDU		Object name	len gth	Scope	Defaults
	Index	Index	Subindex				
Identification data				Supplier ID	2		0x0454
				Device ID	3		0x099CE4
		0x10	0	Supplier name	19	Read only	FAS (Fujian) Co. , LTD
		0x11	0	Supplier text	16		www.fas-elec.com
		0x12	0	Product name	13		FNI IOL-106-002-K20
		0x13	0	Product ID	6		00BS15
		0x14	0	Product text	44		IO-Link IP20 NPN 16DO
		0x16	0	Hardware version	8		20201028
	0x17	0	Firmware version	4	2.00		

Picture 4

3.4 Mistake

As shown in Figure 5.

Error code	Additional code
Device app error 0x80	Index unavailable 0x11
	Subindex unavailable 0x12
	Value out of range 0x30

Picture 5

3.5 Event

As shown in Figure 6.

Class/Qualifier			Code(High Bit + Low Bit)			
Pattern	Type	Instance				
Appear	Error	AL	Hardware	Powered by	Power supply low voltage	U2=Power supply+24V
0xC0	0x30	0x03	0x5000	0x0100	0x0010	0x0002
0xF3			0x5112			
Disappear	Error	AL	Hardware	Powered by	Power supply low voltage	U2=Power supply+24V
0x80	0x30	0x03	0x5000	0x0100	0x0010	0x0002
0xB3			0x5112			
Appear	Error	AL	Hardware	Powered by	Peripheral power supply	
0xC0	0x30	0x03	0x5000	0x0100	0x0060	
0xF3			0x5160			
Disappear	Error	AL	Hardware	Powered by	Peripheral power supply	
0x80	0x30	0x03	0x5000	0x0100	0x0060	
0xB3			0x5160			

Picture 6